



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Manager Emerita

For: Clinton Hill Early Learning Center
30 Demarest St.

Newark, NJ 07112

Laboratory Director:

Attention: Rahveyei McKinnon

Client Number: CLI05E

Report Date: 06/13/2025

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Field Blank

Lab Sample ID: 250603092-01

Site: Collection Date/Time: 06/01/2025 08:36

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/05/25 09:35	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 11:44	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Male Bathroom Sink
FI 2

Lab Sample ID: 250603092-02

Site: Collection Date/Time: 06/01/2025 09:07

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.105 mg/l	1.3	0.0100	0.0048	20044	06/05/25 09:38	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 11:52	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Girls Bathroom inner
Sink FI1

Lab Sample ID: 250603092-03

Site: Collection Date/Time: 06/01/2025 08:54

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0913 mg/l	1.3	0.0100	0.0048	20044	06/05/25 09:49	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 11:55	



Garden State Laboratories, Inc.

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Water Dispenser F1 1

Lab Sample ID: 250603092-04

Site: Collection Date/Time: 06/01/2025 08:37

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0962 mg/l	1.3	0.0100	0.0048	20044	06/05/25 09:53	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 11:58	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Playground Bathroom
Sink

Lab Sample ID: 250603092-05

Site: Collection Date/Time: 06/01/2025 09:00

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0891 mg/l	1.3	0.0100	0.0048	20044	06/05/25 09:57	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:01	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Water Dispenser
Stairwell Rear

Lab Sample ID: 250603092-06

Site: Collection Date/Time: 06/01/2025 09:11

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.103 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:00	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:03	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Maintenance Room
Utility Sink

Lab Sample ID: 250603092-07

Site: Collection Date/Time: 06/01/2025 09:15

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0946 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:04	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:12	



Garden State Laboratories, Inc.

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Counter Sink 235

Lab Sample ID: 250603092-08

Site:

Collection Date/Time: 06/01/2025 09:20

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.131 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:08	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:15	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Handwash Sink 235

Lab Sample ID: 250603092-09

Site:

Collection Date/Time: 06/01/2025 09:22

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0887 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:12	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:17	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Middle Bathroom
Sink 233/235

Lab Sample ID: 250603092-10

Site:

Collection Date/Time: 06/01/2025 09:24

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.138 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:15	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:20	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Counter Sink 233

Lab Sample ID: 250603092-11

Site:

Collection Date/Time: 06/01/2025 09:35

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0916 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:27	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:23	



Garden State Laboratories, Inc.

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Handwash Sink 233

Lab Sample ID: 250603092-12

Site: Collection Date/Time: 06/01/2025 09:37

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.152 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:32	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:26	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Counter Sink 232

Lab Sample ID: 250603092-13

Site: Collection Date/Time: 06/01/2025 09:36

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0932 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:36	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:29	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Bathroom Corner
Sink 232 Side

Lab Sample ID: 250603092-14

Site: Collection Date/Time: 06/01/2025 09:38

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.161 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:39	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:31	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Bathroom Corner
Sink 233 Side

Lab Sample ID: 250603092-15

Site: Collection Date/Time: 06/01/2025 09:40

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.160 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:43	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:34	



Garden State Laboratories, Inc.

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Counter Sink 230

Lab Sample ID: 250603092-16

Site:

Collection Date/Time: 06/01/2025 09:42

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0913 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:47	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:37	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Handwash Sink 232

Lab Sample ID: 250603092-17

Site:

Collection Date/Time: 06/01/2025 09:44

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.136 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:50	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:48	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Counter Sink 222

Lab Sample ID: 250603092-18

Site:

Collection Date/Time: 06/01/2025 10:00

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0712 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:54	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:51	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Handwash Sink 222

Lab Sample ID: 250603092-19

Site:

Collection Date/Time: 06/01/2025 10:02

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.176 mg/l	1.3	0.0100	0.0048	20044	06/05/25 10:58	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:54	



Garden State Laboratories, Inc.

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Middle Bathroom
Sink 222/224

Lab Sample ID: 250603092-20

Site: Collection Date/Time: 06/01/2025 10:04

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.112 mg/l	1.3	0.0100	0.0048	20044	06/05/25 11:02	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 12:57	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Counter Sink 224

Lab Sample ID: 250603092-21

Site: Collection Date/Time: 06/01/2025 10:09

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0898 mg/l	1.3	0.0100	0.0048	20044	06/05/25 11:16	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:03	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Handwash Sink 224

Lab Sample ID: 250603092-22

Site: Collection Date/Time: 06/01/2025 10:11

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.115 mg/l	1.3	0.0100	0.0048	20044	06/05/25 11:27	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:11	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Water Dispenser
(Office) Front

Lab Sample ID: 250603092-23

Site: Collection Date/Time: 06/01/2025 10:15

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0890 mg/l	1.3	0.0100	0.0048	20044	06/05/25 11:31	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:14	



Garden State Laboratories, Inc.

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Counter Sink 210

Lab Sample ID: 250603092-24

Site: Collection Date/Time: 06/01/2025 10:20

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0792 mg/l	1.3	0.0100	0.0048	20044	06/05/25 11:35	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:23	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Handwash Sink 210

Lab Sample ID: 250603092-25

Site: Collection Date/Time: 06/01/2025 10:22

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.184 mg/l	1.3	0.0100	0.0048	20044	06/05/25 11:38	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:26	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Counter Sink 212

Lab Sample ID: 250603092-26

Site: Collection Date/Time: 06/01/2025 10:27

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.117 mg/l	1.3	0.0100	0.0048	20044	06/05/25 11:42	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:28	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Corner Bathroom
Sink 210 Side

Lab Sample ID: 250603092-27

Site: Collection Date/Time: 06/01/2025 10:29

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.146 mg/l	1.3	0.0100	0.0048	20044	06/05/25 11:46	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:31	



Garden State Laboratories, Inc.

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Corner Bathroom
Sink 212 Side

Lab Sample ID: 250603092-28

Site: Collection Date/Time: 06/01/2025 10:31

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.136 mg/l	1.3	0.0100	0.0048	20044	06/05/25 11:50	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:34	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Counter Sink 214

Lab Sample ID: 250603092-29

Site: Collection Date/Time: 06/01/2025 10:38

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0887 mg/l	1.3	0.0100	0.0048	20044	06/05/25 11:53	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:37	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Handwash Sink 214

Lab Sample ID: 250603092-30

Site: Collection Date/Time: 06/01/2025 10:40

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.219 mg/l	1.3	0.0100	0.0048	20044	06/05/25 11:57	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:40	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Bathroom Middle
Sink 214/216

Lab Sample ID: 250603092-31

Site: Collection Date/Time: 06/01/2025 10:42

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.142 mg/l	1.3	0.0100	0.0048	20044	06/05/25 12:08	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:42	



Garden State Laboratories, Inc.

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Counter Sink 216

Lab Sample ID: 250603092-32

Site:

Collection Date/Time: 06/01/2025 10:48

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.101 mg/l	1.3	0.0100	0.0048	20044	06/05/25 12:12	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:45	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Handwash Sink 216

Lab Sample ID: 250603092-33

Site:

Collection Date/Time: 06/01/2025 10:50

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0914 mg/l	1.3	0.0100	0.0048	20044	06/05/25 12:16	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:48	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Dining Area Sink

Lab Sample ID: 250603092-34

Site:

Collection Date/Time: 06/01/2025 10:57

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.103 mg/l	1.3	0.0100	0.0048	20044	06/05/25 12:19	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 13:59	

Sample ID: Clinton Hill Early Learning
Center-30 Demarest St. Newark
NJ 07112 / Dining area
Bathroom

Lab Sample ID: 250603092-35

Site:

Collection Date/Time: 06/01/2025 10:59

Matrix: Potable water

Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.108 mg/l	1.3	0.0100	0.0048	20044	06/05/25 12:23	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 14:02	



Garden State Laboratories, Inc.

Sample ID: Clinton Hill Early Learning Center-30 Demarest St. Newark NJ 07112 / Kitchen Cooking Sink
Lab Sample ID: 250603092-36
Site:
Collection Date/Time: 06/01/2025 11:04
Matrix: Potable water
Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0912 mg/l	1.3	0.0100	0.0048	20044	06/05/25 12:27	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 14:05	

Sample ID: Clinton Hill Early Learning Center-30 Demarest St. Newark NJ 07112 / Kitchen Dishwashing Sink
Lab Sample ID: 250603092-37
Site:
Collection Date/Time: 06/01/2025 11:06
Matrix: Potable water
Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.101 mg/l	1.3	0.0100	0.0048	20044	06/05/25 12:30	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/10/25 14:11	

*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit, MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Clinton Hill Early Learning Center Contact/Authorized by: Rahveyei McKinnon
 Mailing Address: 30 Demarest St. Phone: 862-235-0742
 City/State/Zip: Newark, NJ 07112 Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATI Clinton Hill Early Learning Center - 30 Demarest St. Newark, NJ 07112

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6-3-25 11:07 25.20
 NOEC

Page 1 of 8

GSL CLIENT # CLI05E

MICRO #

CHEM. # 250603092-01-05

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

Grab/Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab #
		Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X	Field Blank	6-1-25	836	X		Lead & Copper (First Draw) 92-01	1	P	250ml	A	
X	MALE BATHROOM SINK FL 2	6-1-25	907	X		Lead & Copper (First Draw) 92-02	1	P	250ml	A	
X	GIRLS BATHROOM INNER SINK FL 1	6-1-25	854	X		Lead & Copper (First Draw) 92-03	1	P	250ml	A	
X	WATER DISPENSER FL 1	6-1-25	837	X		Lead & Copper (First Draw) 92-04	1	P	250ml	A	
X	PLAYGROUND BATHROOM SINK	6-1-25	900	X		Lead & Copper (First Draw) 92-05	1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by:

REPORT FORM: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$ 3700

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other:

Note: **LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED***

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): RAHVEYEI MCKINNON

Signature: [Signature]

Client/Client's Representative (PRINT): RAHVEYEI MCKINNON

Signature: [Signature]

Date/Time: 6-3-25 11:07A

1. Received/Relinquished by (PRINT): F. HARRIS

Signature: [Signature]

Date/Time: 6-3-25 11:10

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN
 IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Clinton Hill Early Learning Center Contact/Authorized by: Rahveyei McKinnon
Mailing Address: 30 Demarest St. Phone: 862-235-0742
City/State/Zip: Newark, NJ 07112 Fax: FH 6-3-25

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATI Clinton Hill Early Learning Center - 30 Demarest St. Newark, NJ 07112

Grab/Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION					Lab #
		Date	Time	AM	PM		No.	Type*	Size	Pres.*	Extension	
X	WATER DISPENSER STAIRWELL REAR	6-1-25	911	X		Lead & Copper (First Draw) 92-06	1	P	250ml	A		
X	MAINTENANCE ROOM UTILITY SINK	6-1-25	915	X		Lead & Copper (First Draw) 92-07	1	P	250ml	A		
X	COUNTER SINK 235	6-1-25	920	X		Lead & Copper (First Draw) 92-08	1	P	250ml	A		
X	HANDWASH SINK 235	6-1-25	922	X		Lead & Copper (First Draw) 92-09	1	P	250ml	A		
X	MIDDLE BATHROOM SINK 235/235	6-1-25	924	X		Lead & Copper (First Draw) 92-10	1	P	250ml	A		

Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Ithiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by: _____

REPORT FORM: ☒ Standard Report ☐ Other/Specify: _____

☐ Standard Report + E2 PWS ID#: _____

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$ SEE PAGE 1

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: _____

Note: **LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED***

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): RAHVEYEI MCKINNON Signature: [Signature] Date/Time: 6-3-25 11:07A
Client/Client's Representative (PRINT): RAHVEYEI MCKINNON Signature: [Signature] Date/Time: 6-3-25 11:10
1. Received/Relinquished by (PRINT): F. HARRIS Signature: [Signature] Date/Time: _____
2. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: _____

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6-3-25 11:10 25.2C
NOE OC

Page 5 of 8

GSL CLIENT # CLI05E

MICRO #

CHEM. # 250603092-06-10

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6-3-25 11:10 25.2C
NOEC

Page 2 of 8

GSL CLIENT # CLI05E

MICRO #

CHEM. # 0250603092-11-15

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Clinton Hill Early Learning Center

Contact/Authorized by: Rahveyei McKinnon

Mailing Address: 30 Demarest St.

Phone: 862-235-0742

City/State/Zip: Newark, NJ 07112

Fax:

FH 6-3-25

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATI Clinton Hill Early Learning Center - 30 Demarest St. Newark, NJ 07112

Grab/Comp		SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION					Lab #
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	Extension	
X		COUNTER SINK 233	6-1-25	935	X		Lead & Copper (First Draw) 92-011	1	P	250ml	A		
X		HANDWASH SINK 233	6-1-25	937	X		Lead & Copper (First Draw) 92-12	1	P	250ml	A		
X		COUNTER SINK 232	6-1-25	936	X		Lead & Copper (First Draw) 92-13	1	P	250ml	A		
X		BATHROOM CORNER SINK SIDE 232	6-1-25	938	X		Lead & Copper (First Draw) 92-14	1	P	250ml	A		
X		BATH ROOM CORNER SINK SIDE 233	6-1-25	940	X		Lead & Copper (First Draw) 92-15	1	P	250ml	A		

* Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify:

Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify:

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by:

REPORT FORM: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$ SEE PAGE 1

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other:

Note: **LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED***

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): RAHVEYEI MCKINNON

Signature:

Client/Client's Representative (PRINT): RAHVEYEI MCKINNON

Signature:

Date/Time: 6-3-25 11:07 A

1. Received/Relinquished by (PRINT): F. K. HARRIS

Signature:

Date/Time: 6-3-25 11:10

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6-3-25 11:10 25.2C
No EOC

Page 6 of 8

GSL CLIENT # CLI05E

MICRO #

CHEM. # 250603092-16-20

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Clinton Hill Early Learning Center

Contact/Authorized by: Rahveyei McKinnon

Mailing Address: 30 Demarest St.

Phone: 862-235-0742

City/State/Zip: Newark, NJ 07112

Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATI Clinton Hill Early Learning Center - 30 Demarest St. Newark, NJ 07112

Grab/Comp		SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab #
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		COUNTER SINK 230	6-1-25	942	X		Lead & Copper (First Draw) 92-16	1	P	250ml	A	
X		HANDWASH SINK 232	6-1-25	944	X		Lead & Copper (First Draw) 92-17	1	P	250ml	A	
X		COUNTER SINK 222	6-1-25	1000	X		Lead & Copper (First Draw) 92-18	1	P	250ml	A	
X		HANDWASH SINK 222	6-1-25	1002	X		Lead & Copper (First Draw) 92-19	1	P	250ml	A	
X		MIDDLE BATHROOM SINK 222/224	6-1-25	1004	X		Lead & Copper (First Draw) 92-20	1	P	250ml	A	

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:

REPORT FORM: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$ SEE PAGE 1

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other:

Note: **LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED***

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): RAHVEYEI MCKINNON

Signature: [Signature]

Client/Client's Representative (PRINT): RAHVEYEI MCKINNON

Signature: [Signature]

Date/Time: 6-3-25 11:07A

1. Received/Relinquished by (PRINT): F. HARRIS

Signature: [Signature]

Date/Time: 6-3-25 11:10

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6-3-25 11:10 25.2C

NOEDC

Page 4 of 8

GSL CLIENT # CLI05E

MICRO #

CHEM. # 250603092-21-25

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Clinton Hill Early Learning Center

Contact/Authorized by: Rahveyei McKinnon

Mailing Address: 30 Demarest St.

Phone: 862-235-0742

City/State/Zip: Newark, NJ 07112

Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATI Clinton Hill Early Learning Center - 30 Demarest St. Newark, NJ 07112

Grab/Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION					Lab #
		Date	Time	AM	PM		No.	Type*	Size	Pres.*	Extension	
X	COUNTER SINK 224	6-3-25	1009	X		Lead & Copper (First Draw) 92-21	1	P	250ml	A		
X	HANDWASH SINK 224	6-3-25	1011	X		Lead & Copper (First Draw) 92-22	1	P	250ml	A		
X	WATER DISPENSER (OFFICE) PAT	6-3-25	1015	X		Lead & Copper (First Draw) 92-23	1	P	250ml	A		
X	COUNTER SINK 210	6-3-25	1020	X		Lead & Copper (First Draw) 92-24	1	P	250ml	A		
X	HANDWASH SINK 210	6-3-25	1022	X		Lead & Copper (First Draw) 92-25	1	P	250ml	A		

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by: _____

REPORT FORM: ☒ Standard Report ☐ Other/Specify: _____

☐ Standard Report + E2 PWS ID#: _____

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$

☐ Composite Fee: \$

☐ Rush Fee: \$

Amount Due: \$ SEE PAGE 1

Payment Method: ☐ Credit Card Type: _____

☐ Check # _____

☐ Other: _____

Note: **LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED***

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): RAHVEYEI MCKINNON

Signature: _____

Client/Client's Representative (PRINT): RAHVEYEI MCKINNON

Signature: _____

Date/Time: 6-3-25 11:07A

1. Received/Relinquished by (PRINT): F. HARRIS

Signature: _____

Date/Time: 6-3-25 11:10

2. Received/Relinquished by (PRINT):

Signature: _____

Date/Time: _____

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6-3-25 11:10 25.2C
NOEC

Page 3 of 8

GSL CLIENT # CLI05E

MICRO #

CHEM. # 250603092-26-30

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Clinton Hill Early Learning Center Contact/Authorized by: Rahveyei McKinnon

Mailing Address: 30 Demarest St. Phone: 862-235-0742

City/State/Zip: Newark, NJ 07112 Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATI Clinton Hill Early Learning Center - 30 Demarest St. Newark, NJ 07112

Grab/Comp		SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION					Lab #
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	Extension	
X		COUNTER SINK 212	6-1-25	1027	X		Lead & Copper (First Draw) 92-26	1	P	250ml	A		
X		CORNER BATHROOM SINK 210 SIDE	6-1-25	1029	X		Lead & Copper (First Draw) 92-27	1	P	250ml	A		
X		CORNER BATHROOM SINK 212 SIDE	6-1-25	1031	X		Lead & Copper (First Draw) 92-28	1	P	250ml	A		
X		COUNTER SINK 214	6-1-25	1038	X		Lead & Copper (First Draw) 92-29	1	P	250ml	A		
X		HANDWASH SINK 214	6-1-25	1040	X		Lead & Copper (First Draw) 92-30	1	P	250ml	A		

Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Thio V = Vial Other/Specify: _____
 Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by:

REPORT FORM: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$ SEE PAGE 1

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other:

Note: **LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED***

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): RAHVEYEI MCKINNON

Signature: [Signature]

Client/Client's Representative (PRINT): RAHVEYEI MCKINNON

Signature: [Signature]

Date/Time: 6-3-25 11:07 A

1. Received/Relinquished by (PRINT): F. HARRIS

Signature: [Signature]

Date/Time: 6-3-25 11:10

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN
 IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN
IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6-3-25 11:07 25.2C
NOE0C

Page 7 of 8

GSL CLIENT # CLI05E

MICRO #

CHEM. # 250603092-31-35

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Clinton Hill Early Learning Center

Contact/Authorized by: Rahveyei McKinnon

Mailing Address: 30 Demarest St.

Phone: 862-235-0742

City/State/Zip: Newark, NJ 07112

Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATI Clinton Hill Early Learning Center - 30 Demarest St. Newark, NJ 07112

Grab/Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION					Lab #
		Date	Time	AM	PM		No.	Type*	Size	Pres.*	Extension	
X	BATHROOM MIDDLE SINK 214	6-3-25	1042	X		Lead & Copper (First Draw) 92-31	1	P	250ml	A		
X	COUNTER SINK 214	6-3-25	1048	X		Lead & Copper (First Draw) 92-32	1	P	250ml	A		
X	HANDWASH SINK 214	6-3-25	1050	X		Lead & Copper (First Draw) 92-33	1	P	250ml	A		
X	DINING AREA SINK	6-3-25	1057	X		Lead & Copper (First Draw) 92-34	1	P	250ml	A		
X	DINING AREA BATHROOM	6-3-25	1059	X		Lead & Copper (First Draw) 92-35	1	P	250ml	A		

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify:

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify:

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by:

REPORT FORM: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$ SEE PAGE 1

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other:

Note: **LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED***

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): RAHVEYEI MCKINNON

Signature: *Rahveyei McKinnon*

Client/Client's Representative (PRINT): RAHVEYEI MCKINNON

Signature: *Rahveyei McKinnon*

Date/Time: 6-3-25 11:07 A

1. Received/Relinquished by (PRINT): F. HARRIS

Signature: *F. Harris*

Date/Time: 6-3-25 11:10

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Clinton Hill Early Learning Center Contact/Authorized by: Rahveyei McKinnon

Mailing Address: 30 Demarest St. Phone: 862-235-0742

City/State/Zip: Newark, NJ 07112 Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATI Clinton Hill Early Learning Center - 30 Demarest St. Newark, NJ 07112

GrabComp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab #
		Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X	KITCHEN COOKING SINK	6-1-25	1104			Lead & Copper (First Draw) 92-36	1	P	250ml	A	
X	KITCHEN DISHWASHING SINK	6-1-25	1106			Lead & Copper (First Draw) 92-37	1	P	250ml	A	

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (if RUSH REQUESTED) Rush Due by:

REPORT FORM: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$ SEE PAGE 1

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other:

Note: **LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED***

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): RAHVEYEI MCKINNON

Signature: *[Signature]*

Client/Client's Representative (PRINT): RAHVEYEI MCKINNON

Signature: *[Signature]*

Date/Time: 1107 am 6/3/25

1. Received/Relinquished by (PRINT): F. HARRIS

Signature: *[Signature]*

Date/Time: 6-3-25 11:10

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6-3-25 11:07 25.2C
 NOEC

Page 8 of 8

GSL CLIENT # CLI05E

MICRO #

CHEM. # 250603092-36,37

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT